STATE OF TENNESSEE
DEPARTMENT OF ENVIRONMENT AND CONSERVATION
DIVISION OF WATER RESOURCES
Cookeville Environmental Field Office
1221 South Willow Avenue
Cookeville, TN 38506
Phone 931-432-4015 Statewide 1-888-891-8332 Fax 931-432-6952

April 15, 2016

Mr. Mike Langford, Owner
Crow Ridge Poultry
328 Lakewood Way
Albany, KY 42602

Subject: **NPDES Tracking Number TNR171801**
Mike Langford Poultry Houses
Monroe, Pickett County, Tennessee

Dear Mr. Langford:

The Division of Water Resources (division) acknowledges receipt of a certified Notice of Termination (NOT) on 01-APR-16, for the above-referenced site. After a review of our files and inspection of the site, it has been determined that this site does not meet the termination requirements as stated in Section 8 of the Construction General Permit (CGP) and we are therefore returning the NOT to you. The entire site is not complete and stable and/or is not covered by replacement coverage (see attached inspection report).

When the site meets the requirements for termination, you may re-submit a NOT. Until that time please note that you are liable for construction related stormwater discharges from the site under the terms and conditions of the CGP.

If you have questions, please contact the division at your local Environmental Field Office at 1-888-891-TDEC; or, at this office, please contact Thomas Huff at (931) 879-0280 or by E-mail at *Thomas.Huff@tn.gov*.

Sincerely,

Johny K. Walker

Johnny K. Walker
Environmental Program Manager

cc: DWR, Cookeville EFO Permit File

TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION
Division of Water Resources
William R. Snodgrass Tennessee Tower, 312 Rosa L. Parks Avenue, 11th Floor, Nashville TN 37243
1-888-891-8332 (TDEC)

Compliance Inspection for General NPDES Permit for Stormwater Discharges from Construction Activities (CGP)

Site/Project Name:	**Crow Ridge Poultry**	**NPDES Tracking Number:**	**TNR171801**
		Date Coverage was Issued	**20-OCT-14**
Street Address or Location:	3198 Old Livingston Highway	**Start date:**	01-FEB-15
		Estimated end date:	31-AUG-15
Site Description:	Site grading for three poultry houses	**Latitude (dd.dddd):**	36.496972
		Longitude (-dd.dddd):	-85.179027
County(ies): Pickett	**EFO:** Cookeville / **MS4 Jurisdiction:**	**Acres Disturbed:**	7.26
		Total Acres:	

Name of Permittee (Developer/Operator): Mike Langford Poultry Houses		
Name of Official Contact: Mike Langford	**Email:** mlangford@overtonpickettcoop.com	**Contact Phone:** 931-688-0566
Address: 328 Lakewood Way	**City:** Albany	**State:** KY **Zip:** 42602

	Check List (office & field checks)	Yes	No	xComments
1	Does the site have CGP coverage?	x	☐	
2	Is NOC posted on site?	☐	☐	A contact person was not on site.
3	Have the site contractors signed the NOI?	x	☐	
4	Is the current SWPPP available for review?	☐	x	No one was available to provide the information.
5	Are EPSCs in accordance with SWPPP?	☐	x	The site was not stable; and didn't have 70% of cover on the site.
6	Are EPSCs installed properly and functional?	☐	x	
7	Are inspection reports available on site?	☐	x	No one was available on site to provide the information.
8	Is the proper buffer zone maintained?	x	☐	
9	Were there unstable, inactive areas on the site? If so, does inspector know if length of time has been more than 14 days (or 7 days for steep slopes)?	☐	x	
10	Are more than 50 acres disturbed at one time?	☐	x	
11	Has sediment discharged off site?	☐	x	
12	Has sediment discharged into waters of the State?	☐	x	
13	Are there unauthorized alterations to waters of the State?	☐	x	
14	Are there violations of an existing ARAP? If so, ARAP No.?	☐	x	
15	Other pollutants/discharges or unusual problems?	☐	x	
16	Project is complete and stable with no construction-related stormwater discharges?	☐	x	

General Comments

Once construction has been completed, the site must be permanently stabilized. All areas disturbed by construction must be finally stabilized with a permanent groundcover sufficient to restrain erosion. Final stabilization is defined in the CGP as a uniform perennial vegetative cover with a uniform density of at least 70 percent of the native (preferably) background vegetative cover for the areas disturbed by construction and areas not covered by permanent structures, and all slopes and channels have been permanently stabilized.

Routine	☐	Comprehensive	☐	Complaint	☐	Follow Up	☐	Termination	x

On-Site Contact (If available)N/A

On-Site Contact Name (Print):	On-Site Contact Title:	Signature:	Date:
n/a			

TDEC Personnel/Information			
Inspector's Name (Print): Thomas S. Huff	**Signature:** Thomas S. Huff	**Date:** 4/5/2016	**EFO: Name and Address** Cookeville Environmental Field Office 1221 South Willow Avenue Cookeville, TN 38506
		Time: 2:30 P.M.	